



CIRCUIT WIRING

- 1: 14/3 AWG NON METALLIC CABLE.
2: CIRCUIT SHALL BE A DEDICATED BRANCH CIRCUIT.
3: CIRCUIT SHALL BE LABELED "SMOKE/CO ALARM CKT." ON DISTRIBUTION PANEL DIRECTORY.
4: A BREAKER LOCK SHALL BE INSTALLED ON THE CIRCUIT BREAKER.

PROJECT INFORMATION		
ALAN HENDERSON		
INSTALLATION CONTRACTOR INFO.		
PEACE OF MIND FIRE & SECURITY SAFETY LLC 167 MIDDLETOWN AVE. NORTH HAVEN, CT 06473 203-901-4350		
NICET CERTIFIED DESIGNER INFO.		
JOSEPH MONTUORI, SET (FIRE ALARM SYSTEMS LEVEL IV) 167 MIDDLETOWN AVE. NORTH HAVEN, CT 06473 NICET ID #: 137011		
DRAWING TITLE		
RISER DIAGRAM		
SCALE:	N.T.S.	
DRAWN BY:	JOSEPH MONTUORI SET	
DATE:	7-28-20	
CHECKED BY:	JDM	
PROJECT #:	1578	
© COPYRIGHT ALL DRAWN AND WRITTEN INFORMATION APPEARING HEREIN SHALL NOT BE DUPLICATED, DISCLOSED, OR OTHERWISE USED WITHOUT THE EXPRESSED WRITTEN CONSENT OF PEACE OF MIND FIRE & SECURITY		FA3.0